

नगर परिषद मलकापूर जि.बुलढाणा (महा.)

(अग्नीशमन विभाग )

Email:-comalkapur@gmail.com

जा.क्रं/मनपा/अग्नीशमन/६९८/२०२१  
दिनांक ०४/०५/२०२१

To,

✓ Yashodham Public School ,  
Wakodi, Malkapur,  
Tal. Malkapur, Dist . Buldana ( M.S.) 443101

**Subject : Fire Safety Certificate**

Ref: 1) Your application dated 26/04/2021

2) Fire Audit of Yashodham Public School, dated 03/05/2021 by **M/s India  
Automation & Fire Solutions.**

**CERTIFICATE**

With reference to above subject as per Ref. No. 1, you have applied for Fire Safety Certificate to us. Accordingly you were instructed to get the fire audit done by certified agency. Accordingly as per Ref. No. 2 we have received fire audit report of M/s India Automation & Fire Solutions dated 03/05/2021.

As per the audit, Yashodham Public School has 3 building (Namely Building A, B, C). Accordingly building "C" is provided with all the required Fire Fighting equipment's. Building "A" & "B" requires some firefighting equipment to be installed as per the report.

**Note: This certificate is valid till 31/10/2021**


**Terms & Conditions :**

- 1 This certificate is issued on the basis of Fire Audit report submitted by M/s India Automation & Fire Solutions.
- 2 Building "A" & "B" should be complied with firefighting equipment as per Annexure -2 of Fire Audit report & same to be conveyed to the dept.
- 3 The school has to comply with all rules / regulations as per the directives issued by Director of Fire services, Maharashtra, Mumbai along with all the Notifications issued by Govt. of Maharashtra from time to time.
- 4 In event of any mishap / Accident due to Noncompliance of terms / Conditions mentioned in this NOC , Nagar Palika , Malkapur won't be responsible for that.


Hence this certificate

With sanction of Hon'ble C.O., Nagar Palika , Malkapur.



  
Incharge Fire officer  
Nagar Parishad, Malkapur  
Dist Buldhana

  
Principal,  
Yashodham Public School,  
MALKAPUR.

  
Manager  
Yashodham Public School  
Malkapur, Dist. Buldhana, (M.S.)

## विनंती अर्ज

प्रति,

मा.फायर इन्वार्ज ऑफीसर,अग्नीशमन विभाग  
नगर परिषद मलकापूर, जिल्हा बुलढाणा

विषय :- फायर सर्टीफीकेट मिळणेबाबत

अर्जदार :- प्राचार्य यशोधाम पब्लीक स्कूल, वाकोडी मलकापूर

महोदय,

मी खालील सही करणार प्राचार्य यशोधाम पब्लीक स्कूल अॅन्ड ज्युनियर कॉलेज मलकापूर जि.बुलढाणा सविनय अर्ज सादर करतो की, आम्हाला आमच्या संस्थेच फायर इन्सपेक्षण करायचे आहे या आधीचे व्हॅलीडीटी ३१.१०.२०२१ पर्यंत होती त्या मध्ये आपण विल्डींग A व B व C विल्डींग मध्ये काही त्रुटी होत्या त्या पुर्ण करण्यास सांगितले होते त्यानुसार आम्ही त्या पुर्ण केल्या आहेत तसेच त्याबाबत ओयस्टर इन्फा कं प्रा. लि. सर्टीफाईड कंपनीचा फायर इन्सपेक्षण रिपोर्ट सोबत जोडला आहे त्या नुसार आपण फायर सर्टीफीकेट द्यावे ही विनंती.

करीता विनंती अर्ज सेवेशी सविनय सादर.


सहपत्र : ओयस्टर इन्फा कं प्रा. लि. सर्टीफाईड कंपनीचा फायर इन्सपेक्षण रिपोर्ट २३..२४.

ठिकान : मलकापूर

दिनांक : 21-8-2023

  
प्राचार्य

यशोधाम पब्लीक स्कूल, मलकापूर

  
Principal,  
Yashodham Public School,  
MALKAPUR

  
29/08/2023  
प्राचार्य यशोधाम पब्लीक  
नगर परिषद, मलकापूर  
जि. बुलढाणा. (443 101)

  
Principal,  
Yashodham Public School,  
MALKAPUR

  
Manager  
Yashodham Public School  
Malkepur, Dist. Buldana. (M.S.)

A1

<b>ANNEXURE 1</b>		
<b>FIRE SAFETY CHECK LIST FOR BUILDINGS</b>		
S#	PARTICULARS	DESCRIPTION
1	NAME OF THE BUILDING	YASHODHAM PUBLIC SCHOOL
2	USE OF BUILDING	B1 - SCHOOL BUILDING
3	ADDRESS	YASHODHAM PUBLIC SCHOOL, YASHODHAM, WAKODI, MALKAPUR, DIST-BULDHANA - 443101
4	TELEPHONE NO.	07267-226285
5	E-MAIL -ID	ypsmalkapur@gmail.com
6	WEBSITE ADDRESS	
7	NAME OF THE BUILDING IN-CHARGE AND TEL. NO.	MR. B RAVISHANKAR MO:7588343972
8	NAME OF ADMINISTRATIVE HEAD AND TEL.NO.	DR.VAIBHAV B. MAHAJAN MO:9765582888
9	BUILDING INCHARGE NAME & TEL. NO.	MR. B RAVISHANKAR MO:7588343972
10	BUILDING OWNER/OCCUPIERS NAME & ADDRESS	MRS. SULOCHANA SWARUPCHAND CHAWARE, VRINDAVAN NAGAR, MALKAPUR, DIST.: BULDANA - 443 101
11	BUILDING TYPE-GOVT/ SEMI GOVT/PRIVATE/ MUNICIPAL/TRUSTEE/CHARITY	PRIVATE
12	BUILDING SPECIALITY IN ANY	B1 - SCHOOL BUILDING
13	BUILDING OCCUPANCY TOTAL NOS.	300 No's STUDENTS
14	<b>BUILDING STRUCTURAL DETAILS</b>	
a)	BUILDING HEIGHT	8.07 MTR. Building: 'A'
b)	NO OF FLOORS	Ground Floor + 01 Floors
c)	TOTAL BUILT-UP AREA	974 SQ.FEETS APPROX.
d)	APPROACH ROAD	06 MTRS.
e)	BUILDING OPEN SPACES	16.2*15.9
	East	SCHOOL GROUND
	West	6 MTRS WIDE ROAD
	South	BLOCK C
	North	6 MTRS WIDE ROAD
f)	NO.OF EXITS (GATE /DOORS/TERRACE ECT.)	EXITS: 02 NO'S
g)	EXIT WIDTH	2.0 MTRS. & 2.5MTRS.
h)	NO. OF STAIRCASE	02 NO'S
i)	STAIRCASE WIDTH	1.5 & 1.6 MTRS.
j)	NATURE OF FLOORING ON EXIT ROUTES	TILES
k)	PARTITIONS IF ANY	N.A.
l)	MATERIAL USED FOR PARTITIONS	N.A.
m)	BASEMENT IF ANY	N.A.
n)	NO. OF BASEMENTS	N.A.
o)	AREA OF BASEMENT	N.A.
15	BASEMENT UTILITY	N.A.
16	MATERIAL STORED IF ANY IN BASEMENT	N.A.
17	TOTAL NO OF ROOMS/FLOORS	17 ROOMS (GR.: 10 NO'S & 1ST: 07 NO'S)
18	TOTAL NO. OF ROOMS IN BUILDING	17 ROOM.

*[Signature]*  
Principal,  
Yashodham Public School,

*[Signature]*  
Manager  
Yashodham Public School,  
Malkapur Dist. Buldana, (M.A.)

**FIRE FIGHTING SYSTEM | FIRE DETECTION SYSTEM | PASSIVE FIRE PROTECTION SYSTEM | PROJECT CONSULTANCY | FABRICATION & ERECTION | DESIGN & DEVELOPMENT**

Regd. Office : 2249/B 23-24, Shrikrushna Nagar, Nagpur- 440 009. (Maharashtra)  
Branch Office : Plot No. 6, Rajiv Gruh Nirman Housing Society, Ashtavinayak Nagar, Jaitala Road, Nagpur - 440036 (Maharashtra)  
 : 3. Swapnalok Complex, Near Inox Multiplex, Wardhaman Nagar, Nagpur - 440008 (Maharashtra).  
Contact : ☎ 0712-2775785 ☐ +91-9960117744, 9403677401 ✉ oyster.infracon@gmail.com



20/11/18  
Am-1

S#	PARTICULARS	DESCRIPTION
19	NO OF TOILETS PER FLOOR	GR.: 05 & 1ST: 02 No's
20	EXTERIOR FACADING/CLADDING OF BUILDING-GLASS	NO
21	OVER HEAD WATER TANK CAPACITY	10,000 LTRS.
22	UNDERGROUND WATER TANK CAPACITY	NO
23	BUILDING INTERIOR NATURE	BRICK WALLS WITH PLASTER
24	NO.OF LIFTS WITH CAPACITY	N.A.
a)	PASSANGER LIFTS	N.A.
b)	FIRE LIFTS	N.A.
c)	STRETCHER LIFTS IF ANY	N.A.
d)	ANY OTHER LIFTS	N.A.
25	ELECTRICAL WIRING / INSTALLATION AUDIT / ELECTRICAL INSPECTORS	N.A.
26	ANNUAL TEST REPORT-COPY	N.A.
27	INTERIOR LOCATION	N.A.
28	CANTEEN/PANTRY/KITCHEN LOCATION & AREA	N.A.
29	FUEL USED NO. OF CYLINDERS LOCATION	N.A.
30	ANY OTHER ASSEMBLY AREAS/LOCATION	MAIN ENTRANCE OF BUILDING
31	STORE ROOM LOCATION	GROUND FLOOR
32	STORE ROOM AREA STORAGE TYPE	100.00 SQ. FEET. DOCUMENTS ONLY
33	TRANSFORMER/GENERATOR LOCATION WITH CAPACITY & TYPE	GENERATOR:01 NO'S (25 kVA)
34	AIR-CONDITIONING TYPE WINDOW/SPLIT/CENTRAL AC ETC	NO
35	BUILDING UTILITIES	B1 - SCHOOL BUILDING
36	NO. OF CINEMA THEATRES /HALLS/OPERATION THEATRES	HALLS: 02 NO'S
37	TOTAL NO OF SEATING ARRANGEMENT /BENCHES	300 SEATING
38	NO.OF MAX OCCUPANCIES IN BUILDING	300 STUDENTS + STAFF
39	NO.OF VISITORS (FLOATING POPULATION)	300 STUDENTS + STAFF
40	MACHINERY IF ANY	N.A.
a)	NAME	N.A.
b)	QTY	N.A.
c)	STORAGE	N.A.
d)	PLACE ETC	N.A.
41	TYPE/DETAILS OF MATERIAL STORED IN STOREROOM (ACIDS/ALAKALIS/TOXIC/INFLAMMABLE ETC)	ONLY DOCUMENTS
42	LPG/CNG ETC GAS STORAGE DETAILS (GAS NAME QTY ETC)	LPG: 02 NO'S
43	GAS UTILITY	SCIENCE LAB
44	TOTAL NO OF EMPLOYEES	125 NO'S
45	NO OF TOTAL STAFF SHIFT WISE	GENERAL: 124 NIGHT: 01
46	NO. OF SECURITY STAFF SHIFTWISE	DAY: 2 NO'S. & NIGHT: 01 NO'S
47	PERMISSIONS & APPROVALS	
48	WHETHER BUILDING PLANS SANCTIONED BY COMPENTENT AUTHORITY/GOVT (COPY OF SANCTIONED PLAN)	YES
49	WHETHER FINAL NOC OBTAINED IF YES SUBMIT COPY	N.A.
50	BUILDING COMPLETION CERTIFICATE OBTAINED (YES/NO), IF YES, SUBMIT COPY	N.A.




*[Signature]*  
Principal,  
Yashodham Public School,  
MALKAPUR.






*[Signature]*  
Manager  
Yashodham Public School  
Malkapur Dist. Buldana, (M.S.)





S#	PARTICULARS	DESCRIPTION			
ii)	RESPONSIBLE PERSON IN CASE OF EMERGENCY	SUPPORTING STAFF / RESIDENT WATCHMEN			
	i) NAME,	NA			
	ii) ADDRESS	ON DUTY STAFF			
	iii) MOB NO.	NA			
	iv) IS THE FIRE OFFICER EMPLOYED?	NO			
h)	DETAILS ABOUT FIRE OFFICER	NO			
	i) NAME	NA			
	ii) ADDRESS	NA			
	iii) MOB NO.	NA			
	iv) QUALIFICATION & EXPERIENCE	NA			
	j) SAFETY OFFICER/SECURITY OFFICER	NA			
	i) NAME	NA			
	ii) ADDRESS	NA			
	iii) MOB NO.	NA			
	iv) QUALIFICATION & EXPERIENCE	NA			
56	REFUGE AREA, IF ANY LOCATION AREA ETC.	CENTRAL ASSEMBLY AREA			
57	ASSEMBLY POINT IDENTIFIED ON GROUND LOCATION	YES			
58	LIST OF OTHER STAFF TRAINED FOR HANDLING FIRE RELATED EMERGENCIES	SANDIP MUNDHE, RAJESH CHOPADE, DHIRAJ CHAWARE, GOPAL BHOMBE			
59	WHETHER ADEQUATE FIRE & SAFETY DIRECTIONAL SIGNAGES BOARDS INSTALLED (YES/NO)	NO			
60	NO. OF AMBULANCES IF ANY WITH CAPACITY	NA			
61	NO. OF OTHER VEHICLES, THAT CAN BE UTILIZED IN CASE OF EMERGENCY	2			
62	NO. OF TYPES OF SMOKE MASKS				
63	WHETHER ASSEMBLY POINT IS MARKED CLEARLY-YES/NO	YES			
64	IS LICENSED AGENCY APPOINTED FOR SIX MONTHLY INSPECTION-YES/NO.	YES			
65	NAME AND DETAILS OF LICENSED AGENCY	OYSTER INFRACON PVT. LTD.			
66	ADDITIONAL OBSERVATIONS, IF ANY	AS PER ANNEXURE 2			
67	RECOMMENDATIONS IF ANY (NOTE: - FOR DETAILED OBSERVATIONS AND RECOMMANDATIONS SEPARATE SHEET SHOULD BE ATTACHED IF NECESSARY)				
Audit By:					
<table border="1"> <tr> <td>OYSTER INFRACON PVT. LTD.</td> </tr> <tr> <td>LICENCE NO. - MPS-LA/2021/RF-271</td> </tr> <tr> <td>LICENCE NO. - MPS-LA/2021/RD-249</td> </tr> </table>		OYSTER INFRACON PVT. LTD.	LICENCE NO. - MPS-LA/2021/RF-271	LICENCE NO. - MPS-LA/2021/RD-249	 Manager Yashodham Public School Molkepur Dist. Buldana, (M.S) BUILDING INCHARGE
OYSTER INFRACON PVT. LTD.					
LICENCE NO. - MPS-LA/2021/RF-271					
LICENCE NO. - MPS-LA/2021/RD-249					
 INSPECTION AUTHORITY (SIGN & SEAL) PRANAY TADSE (M:+91-95619 26002)					
OYSTER INFRACON PVT. LTD.					
		 Manager			

Sl#	PARTICULARS	DESCRIPTION			
g)	RESPONSIBLE PERSON IN CASE OF EMERGENCY	SUPPORTING STAFF / RESIDENT WATCHMEN			
	i) NAME,	NA			
	ii) ADDRESS	ON DUTY STAFF			
	iii) MOB NO.	NA			
iv)	IS THE FIRE OFFICER EMPLOYED?	NO			
h)	DETAILS ABOUT FIRE OFFICER	NO			
	i) NAME	NA			
	ii) ADDRESS	NA			
	iii) MOB NO.	NA			
iv)	QUALIFICATION & EXPERIENCE	NA			
i)	SAFETY OFFICER/SECURITY OFFICER	NA			
	i) NAME	NA			
	ii) ADDRESS	NA			
	iii) MOB NO.	NA			
iv)	QUALIFICATION & EXPERIENCE	NA			
56	REFUGE AREA, IF ANY LOCATION AREA ETC.	CENTRAL ASSEMBLY AREA			
57	ASSEMBLY POINT IDENTIFIED ON GROUND LOCATION	YES			
58	LIST OF OTHER STAFF TRAINED FOR HANDLING FIRE RELATED EMERGENCIES	SANDIP MUNDHE, RAJESH CHOPADE , DHIRAJ CHAWARE, GOPAL BHOMBE			
59	WHETHER ADEQUATE FIRE & SAFETY DIRECTIONAL SIGNAGES BOARDS INSTALLED (YES/NO)	NO			
60	NO. OF AMBULANCES IF ANY WITH CAPACITY	NA			
61	NO. OF OTHER VEHICLES, THAT CAN BE UTILIZED IN CASE OF EMERGENCY	2			
62	NO.OF TYPES OF SMOKE MASKS				
63	WHETHER ASSEMBLY POINT IS MARKED CLEARLY-YES/NO	YES			
64	IS LICENSED AGENCY APPOINTED FOR SIX MONTHLY INSPECTION-YES/NO.	YES			
65	NAME AND DETAILS OF LICENSED AGENCY	OYSTER INFRACON PVT. LTD.			
66	ADDITIONAL OBSERVATIONS, IF ANY	AS PER ANNEXURE 2			
67	RECOMMENDATIONS IF ANY (NOTE: - FOR DETAILED OBSERVATIONS AND RECOMMANDATIONS SEPARATE SHEET SHOULD BE ATTACHED IF NECESSARY)				
Audit By:					
<table border="1"> <tr> <td>OYSTER INFRACON PVT. LTD.</td> </tr> <tr> <td>LICENCE NO. - MF5-1A/2021/RP-271</td> </tr> <tr> <td>LICENCE NO - MF5-1A/2021/RD-249</td> </tr> </table>			OYSTER INFRACON PVT. LTD.	LICENCE NO. - MF5-1A/2021/RP-271	LICENCE NO - MF5-1A/2021/RD-249
OYSTER INFRACON PVT. LTD.					
LICENCE NO. - MF5-1A/2021/RP-271					
LICENCE NO - MF5-1A/2021/RD-249					
 <b>INSPECTION AUTHORITY (SIGN &amp; SEAL)</b> PRANAY TADSE (M:+91-95619 26002) OYSTER INFRACON PVT. LTD.		 <b>Manager</b> Yashodham Public School, Malkapur Dist. Buldana.(M.S) BUILDING INCHARGE			
		 <b>Manager</b> Yashodham Public School Malkapur Dist. Buldana.(M.S.)			



A 2

**ANNEXURE 2**  
**INSPECTION REPORT**

1	Name & Address of the Building	YASHODHAM PUBLIC SCHOOL, YASHODHAM, WAKODI, MALKAPUR, DIST BULDHANA - 443101
2	Type of Occupancy	SCHOOL BUILDING - B1 TYPE
3	Details of previous Fire NOC Letter No.	जा.क्र./मनपा/अब्जीशमन/६९८/२०२१, दिनांक : ०४/०५/२०२१
4	Fire Safety directives letter No	NIL
5	Date of Inspection	14-08-2023
6	Names of the Inspecting Officers/ AGENCY	OYSTER INFRACON PVT. LTD.
7	Names and Designation of Officers if any, representing the Owner/ Occupier of the Building	MR. PRANAY TADSE MR. B RAVISHANKAR MO:7588343972
8	Year of Construction	2008 - 09

S#	MINIMUM STANDARDS FOR FIRE PREVENTION AND FIRE SAFETY	REQUIREMENT AS PER NBC 2005	PROVIDED AT SITE	REMARKS MEETS/DOESN'T MEET REQUIREMENT
1	Access to building			
	Road width	6 MTRS	YES	MEETS
	Gate width	1.5 MTR	YES	MEETS
	Width of internal road	NOT SPECIFIED	N.R.	
2	Means of egress			
	Number of staircases	NOT SPECIFIED	02 NO'S	MEETS
	Upper Floors	NOT SPECIFIED	02 NO'S	MEETS
	Basements	NOT SPECIFIED		
	Width of staircases			
	Upper Floors	NOT SPECIFIED	1.50 MTR	MEETS
	Basements	NOT SPECIFIED	N.A.	
	Protection of exits			
	Fire check door	NOT SPECIFIED	NA	
	Pressurization	NOT SPECIFIED	NA	
	No. of continuous staircases to terrace	ONE	TWO	
	Staircase lobby	NOT SPECIFIED	1.50 MTRS.	MEETS
	Width of Corridor	NOT SPECIFIED	2.50 MTR	MEETS
	Door Size	1 MTR	YES	MEETS
3	Compartmentation	NOT SPECIFIED	NA	MEETS
	Fire check door	---	NA	
	Sealing of electrical shafts	---	NA	
	Fire Rating of shaft door	---	NA	
	Size of compartment	---	NA	
	Fire Dampers	---	NA	
4	Smoke Management System.	NOT REQUIRED	NA	
	Basements	30A/C PER HOUR	NA	
	Upper floors	12A/C PER HOUR	NA	

*Yashodham Public School, Malkapur, Dist. Buldhana*

*Yashodham Public School, Malkapur, Dist. Buldhana*

**FIGHTING SYSTEM | FIRE DETECTION SYSTEM | PASSIVE FIRE PROTECTION SYSTEM | PROJECT CONSULTANCY | FABRICATION & ERECTION | DESIGN & DEVELOPMENT**


Head Office : 2249/B 23-24, Shrikrushna Nagar, Nagpur- 440 009. (Maharashtra)  
 Branch Office : Plot No. 6. Rajiv Gruh Nirman Housing Society, Ashtavinayak Nagar, Jaitala Road, Nagpur - 440036 (Maharashtra)  
 : 3. Swapnalok Complex. Near Inox Multiplex, Wardhaman Nagar, Nagpur - 440008 (Maharashtra)  
 Contact : ☎ 0712-2775785 ☐ +91-9960117744, 9403677401 ✉ oyster.infracon@gmail.com

10/10/2

Sl#	MINIMUM STANDARDS FOR FIRE PREVENTION AND FIRE SAFETY	REQUIREMENT AS PER NBC 2005	PROVIDE ) AT SITE	REMARKS MEETS/DOESN'T MEET REQUIREMENT
5	Fire Extinguishers	REQUIRED	YES	MEETS
	Total Numbers	NOT SPECIFIED	08 NO'S	MEETS
	Types	ABC/CO2/DCP	ABC, CO2	MEETS
	ISI marking	ISI MARKED	YES	MEETS
6	First-Aid Hose Reels.	REQUIRED	01 NOS. ON EACH FLOOR	MEETS
	Total numbers on each floor	AS PER AREA		
	Length of hose reel hose	30 MTRS	30 MTRS	MEETS
	Nozzle diameter	5 MM	63 MM	MEETS
7	Automatic Fire detection and Fire alarm.	NOT REQUIRED	YES, FIRE ALARM SYSTEM	
	Type of Detectors	SMOKE/ HEAT		
	Location of Main Panel	G.F.	ON EACH FLOOR	MEETS
	Location of Repeater Panel	---	NA	
	Alternate source of power	---	24V DC BATTERY	MEETS
	Hooters' Location	GF	ON EACH FLOOR	MEETS
	8	Manually Operated Electrical Fire Alarm.	NOT REQUIRED	YES, ON EACH FLOOR
9	Public Address System.	NOT SPECIFIED		
10	Automatic Sprinkler System.	NOT REQUIRED	NA	
	Basement	---		
	Upper Floor	---		
	Sprinkler above false ceiling	---		
11	Internal Hydrants	NOT REQUIRED	NA	
	Size of riser/down-comer	---		
	Number of hydrants per floor	---		
	Hose Box	---		
12	Yard Hydrants.	NOT REQUIRED	NA	
	Total Number of Hydrants	---		
	Hose Box	---		
13	Pumping Arrangements.			
	Ground Level	NOT REQUIRED	AT TERRACE LEVEL	
	Discharge of Main Pump	---	900 LMP	
	Head of Main pump	---	15 MTRS	
	Number of main pumps	---	01 NOS.	
	Jockey Pump out put	---	NA	
	Jockey pump head	---	NA	
	Standby / Diesel Engine Pump out put	---	NA	
	Standby / Diesel Engine Pump Head	---	NA	
	Auto Starting/ Manual stopping	---	NA	
	Pump House Access	---	NA	
	Terrace level	REQUIRED	AT TERRACE LEVEL	MEETS
	Discharge of pump	450 LPM	900 LMP	MEETS
	Head of the pump	56 MTR.	15 M TRS	MEETS
	Power Supply	---	BY D. G. SET	MEETS
	Auto Starting of pump	---		
	14	Captive Water Storage for fire fighting	NOT EQUIRED	
Underground tank capacity		---		
Draw-off connection		---		
Fire service inlet		REQUIRED	01 NOS. AT ENTRANCE OF BUILDING	MEETS
Access to tank		---		

Fire Audit Report  
*[Signature]*  
 Principal,  
 Yashodham Public School,  
 MALKAPUR

*[Signature]*  
 Manager  
 Yashodham Public School  
 Malkapur Dist. Bidhana (M.S)



S#	MINIMUM STANDARDS FOR FIRE PREVENTION AND FIRE SAFETY	REQUIREMENT AS PER NBC 2005	PROVIDED AT SITE	REMARKS MEETS/DOESN'T MEET REQUIREMENT
15	Overhead Tank capacity (EXCLUSIVELY FOR FIRE FIGHTING) Exit Signage	10,000 LTRS	10,000 LTRS	MEETS
16	Provision of Lifts	REQUIRED	PROVIDED AT SITE	MEETS
	Pressurization of Lift Shaft	NOT REQUIRED	NA	
	Pressurization of Lift lobby	---		
	Communication facility In lift Car	---		
	Fireman's Grounding Switch	---		
	Lift Signages	---		
17	Standby power supply	REQUIRED	D. G. SET PROVIDED AT SITE	MEETS
18	Refuge Area.	NOT APPLICABLE	YES,	
	Total Area	---		
	Location	---	CENTRAL ASEMBLY AREA AT GROUND FLOOR	MEETS
19	Fire Control Room	NOT REQUIRED	NA	
	Control Panel	---		
	Detector System	REQUIRED	MANUAL FIRE ALARM SYSTEM	MEETS
	Flow Switch Panel	---	NA	
	PA System Panel	---	NA	
	Batter backup, if any	REQUIRED	PROVIDED AT SITE	MEETS
	Building Floor Plans	---		
20	Special Fire Protection Systems for Protection of Special Risks.	NOT REQUIRED	NA	

The fire protection systems should be provided. And Keeping in view the extent of compliance of the minimum standards on fire prevention and fire safety required under the Rules.

The fire protection equipment mentioned above is provided at the time of inspection of the building / premises. Considering the limits of compliance with the minimum standards of fire prevention and fire safety required by the rules, it is proposed as follows. - NIL

Audit By:

OYSTER INFRACON PVT. LTD.

LICENCE NO. - MFS-LA/2021/RF-271


LICENCE NO. - MFS-LA/2021/RD-249



NAME & SIGNATURE OF THE INSPECTING OFFICER

PRANAY TADSE (M:+91-95619 26002)

OYSTER INFRACON PVT. LTD.



Manager  
Yashodham Public School  
Malkapur Dist. Daldona. (M.S)



Principal,  
Yashodham Public School,  
MALKAPUR



Manager  
Yashodham Public School  
Malkapur Dist. Daldona. (M.S)



B<sub>1</sub>

ANNEXURE 1		
FIRE SAFETY CHECK LIST FOR BUILDINGS		
S#	PARTICULARS	DESCRIPTION
1	NAME OF THE BUILDING	YASHODHAM PUBLIC SCHOOL
2	USE OF BUILDING	B1 - TYPE - SCHOOL BUILDING
3	ADDRESS	YASHODHAM PUBLIC SCHOOL, YASHODHAM, WAKODI, MALKAPUR, DIST-BULDHANA - 443101
4	TELEPHONE NO.	07267-226285
5	E-MAIL -ID	ypsmalkapur@gmail.com
6	WEBSITE ADDRESS	
7	NAME OF THE BUILDING IN-CHARGE AND TEL. NO.	MR. B RAVISHANKAR MO:7588343972
8	NAME OF ADMINISTRATIVE HEAD AND TEL.NO.	DR.VAIBHAV B. MAHAJAN MO:9765582888
9	BUILDING INCHARGE NAME & TEL. NO.	MR. B RAVISHANKAR MO:7588343972
10	BUILDING OWNER/OCCUPIERS NAME & ADDRESS	MRS. SULOCHANA SWARUPCHAND CHAWARE, VRINDAVAN NAGAR, MALKAPUR, DIST. BULDANA - 443 101
11	BUILDING TYPE-GOVT/ SEMI GOVT/PRIVATE/ MUNICIPAL/TRUSTEE/CHARITY	PRIVATE
12	BUILDING SPECIALITY IN ANY	B1 - TYPE - SCHOOL BUILDING
13	BUILDING OCCUPANCY TOTAL NOS.	800 No's STUDENTS
14	<b>BUILDING STRUCTURAL DETAILS</b>	
a)	BUILDING HEIGHT	10.36 MTR. Building: 'B'
b)	NO OF FLOORS	GR + 02 Floors
c)	TOTAL BUILT-UP AREA	2505 SQ.MTR APPROX.
d)	APPROACH ROAD	06 MTRS.
e)	BUILDING OPEN SPACES	
i	EAST	6.00 MTR ROAD
ii	WEST	SCHOOL GROUND
iii	SOUTH	SCHOOL GROUND
iv	NORTH	6.00 MTR ROAD
f)	NO.OF EXITS (GATE /DOORS/TERRACE ECT.)	EXITS: 03 NO'S
g)	EXIT WIDTH	7.2 MTRS. & 2.4MTRS. & 1.6 MTRS
H)	NO. OF STAIRCASE	03 NO'S
I)	STAIRCASE WIDTH	2 no. 1.5 MTRS. & 1.00 MTRS. 1 no.
J)	NATURE OF FLOORING ON EXIT ROUTES	TILES
k)	PARTITIONS IF ANY	NA
l)	MATERIAL USED FOR PARTITIONS	NA
m)	BASEMENT IF ANY	NO
n)	NO. OF BASEMENTS	NO
o)	AREA OF BASEMENT	N.A.
15	BASEMENT UTILITY	N.A.
16	MATERIAL STORED IF ANY IN BASEMENT	N.A.
17	TOTAL NO OF ROOMS/FLOORS	33 ROOMS (GR.: 11 NO'S , 1ST: 12 NO'S & 2nd : 10 NO'S)
18	TOTAL NO. OF ROOMS IN BUILDING	33 ROOM.

*Principal,*  
Yashodham Public School,  
MALKAPUR

*Manager*  
Yashodham Public School  
Malkapur, Dist. Buldhana (MS)

*Pradeep*

RE FIGHTING SYSTEM | FIRE DETECTION SYSTEM | PASSIVE FIRE PROTECTION SYSTEM | PROJECT CONSULTANCY | FABRICATION & ERECTION | DESIGN & DEVELOPMENT

Regd. Office : 2249/B 23-24, Shrikrushna Nagar, Nagpur- 440 009. (Maharashtra)  
Branch Office ♦ : Plot No. 6, Rajiv Gruh Nirman Housing Society, Ashtavinayak Nagar, Jaitala Road, Nagpur - 440036 (Maharashtra)  
♦ : 3. Swapnalok Complex, Near Inox Multiplex, Wardhaman Nagar, Nagpur - 440008 (Maharashtra)  
Contact : ☎ 0712-2775785 ☐ +91-9960117744, 9403677401 ✉ oyster.infracon@gmail.com

Wine B  
Ann 17

S#	PARTICULARS	DESCRIPTION
19	NO OF TOILETS PER FLOOR	GR.: 03, 1ST: 02 No's, 2nd : 1 No's
20	EXTERIOR FACADING/CLADDING OF BUILDING-GLASS	
21	OVER HEAD WATER TANK CAPACITY	11,000 LTRS.
22	UNDERGROUND WATER TANK CAPACITY	NO
23	BUILDING INTERIOR NATURE	
24	NO.OF LIFTS WITH CAPACITY	NO.
a)	PASSANGER LIFTS	NO
b)	FIRE LIFTS	NO
c)	STRETCHER LIFTS IF ANY	NO
d)	ANY OTHER LIFTS	NA
25	ELECTRICAL WIRING / INSTALLATION AUDIT / ELECTRICAL INSPECTORS	NO
26	ANNUAL TEST REPORT-COPY	NO
27	INTERIOR LOCATION	
28	CANTEEN/PANTRY/KITCHEN LOCATION & AREA	N.A.
29	FUEL USED NO. OF CYLINDERS LOCATION	NO
30	ANY OTHER ASSEMBLY AREAS/LOCATION	MAIN ENTRANCE OF BUILDING
31	STORE ROOM LOCATION	GR. FLOOR
32	STORE ROOM AREA STORAGE TYPE	11.00 SQ. MTR. DOCUMENTS ONLY
33	TRANSFORMER/GENERATOR LOCATION WITH CAPACITY & TYPE	GENERATOR:01 NO'S (25 KVA)
34	AIR-CONDITIONING TYPE WINDOW/SPLIT/CENTRAL AC ETC	NO
35	BUILDING UTILITIES	B1 - TYPE - SCHOOL BUILDING
36	NO. OF CINEMA THEATRES /HALLS/OPERATION THEATRES	HALLS: 01NO'S
37	TOTAL NO OF SEATING ARRANGEMENT /BENCHES	800 SEATINGS
38	NO.OF MAX OCCUPANCIES IN BUILDING	800 STUDENTS + STAFFS
39	NO.OF VISITORS (FLOATING POPULATION)	800 STUDENTS + STAFFS
40	MACHINERY IF ANY	N.A.
a)	NAME	N.A.
b)	QTY	N.A.
c)	STORAGE	N.A.
d)	PLACE ETC	N.A.
41	TYPE/DETAILS OF MATERIAL STORED IN STOREROOM (ACIDS/ALAKALIS/TOXIC/INFLAMMABLE ETC)	ONLY DOCUMENTS
42	LPG/CNG ETC GAS STORAGE DETAILS (GAS NAME QTY ETC)	NO
43	GAS UTILITY	N.A
44	TOTAL NO OF EMPLOYEES	125 NO'S
45	NO OF TOTAL STAFF SHIIFT WISE	GENERAL: 124 NIGHT: 01
46	NO. OF SECURITY STAFF SHIIFTWISE	DAY: 00 NO'S. & NIGHT: 01 NO'S
47	PERMISSIONS & APPROVALS	
48	WHETHER BUILDING PLANS SANCTIONED BY COMPETENT AUTHORITY/GOVT (COPY OF SANCTIONED PLAN)	YES
49	WHETHER FINAL NOC OBTAINED IF YES SUBMIT COPY	N.A.
50	BUILDING COMPLETION CERTIFICATE OBTAINED (YES/NO), IF YES, SUBMIT COPY	N.A.

Principal,  
Yashodham Public School,  
Malkapur, Dist. Buldana, (M.S.)

Manager  
Yashodham Public School  
Malkapur, Dist. Buldana, (M.S.)





S#	PARTICULARS	DESCRIPTION
51	<b>FIRE FIGHTING INSTALLATION DETAILS</b>	
52	<b>ACTIVE FIRE PROTECTION</b>	<b>FIRE EXTINGUISHERS: 14 NO'S ONLY</b>
		FIRE EXTINGUISHERS: 14 NO'S ONLY
a)	WHETHER FIXED FIRE FIGHTING SYSTEM (RISER - DOWN COMER) INSTALLED YES/NO	<b>YES, DOWNCOMMER SYSTEM WITH 01 NOS HOSE REEL ON EACH FLOOR.</b>
b)	FIRE SMOKE DETECTORS /SPRINKLERS/MANNUAL CALL POINTS/PA SYSTEM INSTALLED	<b>YES, MANUAL FIRE ALARM SYSTEM WITH 01 NOS. MCP &amp; HOOTERS ON EACH FLOOR.</b>
c)	SPECIAL PUBLIC ADDRESS SYSTEM INSTALLED IF ANY	<b>NO</b>
d)	IF YES, IS IT IN OPERATING /WORKING CONDITION	<b>NA</b>
e)	FIRE FIGHTING PUMP DETAILS (ELECTRIC/DIESEL, OUTPUT, HP, HEAD, ETC)	<b>YES, 01 NOS. MAIN ELECTPIC PUMP with 900 LPM 15 MTRS HEAD.</b>
i)	MAIN PUMP	<b>YES, 01 NOS.</b>
ii)	JOCKEY PUMP	<b>NO</b>
iii)	SPRINKLER PUMP	<b>NO</b>
iv)	STAND BY PUMP	<b>NO</b>
v)	DIESEL PUMP	<b>NO</b>
f)	EMERGENCY BACKUP ARRANGEMENT	<b>NO</b>
g)	WHETHER FIRE SYSTEM & EMERGENCY LIGHTING ATTACHED TO EMERGENCY BACKUP	<b>NA</b>
h)	FIRE FIGHTING WATER TANK CAPACITY	<b>10,000 LTRS.</b>
i)	IF YES, DATE OF LAST TESTING	<b>NO</b>
j)	NO.OF LOCATION OF FIRE EXTINGUISHERS	<b>14 NOS</b>
	TYPE OF EXTINGUISHERS LAST INSPECTED	<b>ABC-6 Kg. = 01NO'S, ABC-04 Kg = 10 No's, ABC-05 KG = 03 NO'S, CO2-4.5KG. = 00NO'S DT.: 14/08/23</b>
53	<b>WHETHER AUTOMATIC FIRE DAMPERS PROVIDED IN CENTRAL AC DUCTS</b>	<b>NO</b>
a)	CONNECTED TO DETECTION SYSTEM	<b>NA</b>
b)	LAST INSPECTED / MAINTENANCE CARRIED OUT	<b>NA</b>
54	<b>OTHER INFORMATION</b>	
a)	FIRE LIFT, IF ANY	<b>NO</b>
b)	ELECTRICAL MCB/ACB/ELCB PROVIDED	<b>YES</b>
c)	FIRE STOP /RESISTING DOORS PROVIDED	<b>NO</b>
d)	IF YES, RATING OF DOORS HRS	<b>NA</b>
e)	WHETHER FIRE PLANS INSTALLED IN EACH WARD	<b>NO</b>
f)	WHETHER FIRE EMERGENCY INSTRUCTIONS BOARD INSTALLED ON EVERY FLOOR	<b>NO</b>
g)	VERTICAL SHAFTS SEALED	<b>NA</b>
h)	FIRE STAFF PROVIDED IF YES, NOS.	<b>NO</b>
i)	NO. OF STAFF TRAINED FOR BASIC FIRE FIGHTING	<b>05 NO'S</b>
j)	SECURITY STAFF TRAINED	<b>01 NO'S</b>
55	<b>FIRE PREVENTION &amp; AWARENESS MEASURES</b>	
a)	FIRE MOCK DRILL CONDUCTED IF ANY - YES/NO	<b>YES</b>
b)	IF YES, DATE OF RECENT DRILL-SUBMIT REPORT	<b>DATE: 09/12/2022, Photos attached</b>
c)	WHETHER EVACUATION DRILL CONDUCTED, YES/NO	<b>NO</b>
d)	IF YES, INDICATE PERIODICITY.	<b>NO</b>
e)	IF YES, DATE OF RECENT DRILL-SUBMIT REPORT	<b>NA</b>
f)	ON SITE EMERGENCY PLAN-ATTACH COPY	<b>NO</b>

*Bow*  
Principal,  
Yashodham Public School,  
MALIKAPUR

*CM*  
Manager  
Yashodham Public School  
Malikapur Dist.Buldana.(M.S)






S#	PARTICULARS	DESCRIPTION
g)	RESPONSIBLE PERSON IN CASE OF EMERGENCY	
i)	NAME,	SUPPORTING STAFF / RESIDENT WATCHMEN
ii)	ADDRESS	NA
iii)	MOB NO.	ON DUTY STAFF
iv)	IS THE FIRE OFFICER EMPLOYED?	NA
h)	DETAILS ABOUT FIRE OFFICER	NO
i)	NAME	NO
ii)	ADDRESS	NA
iii)	MOB NO.	NA
iv)	QUALIFICATION & EXPERIENCE	NA
i)	SAFETY OFFICER/SECURITY OFFICER	NA
i)	NAME	NA
ii)	ADDRESS	NA
iii)	MOB NO.	NA
iv)	QUALIFICATION & EXPERIENCE	NA
56	REFUGE AREA, IF ANY LOCATION AREA ETC.	
57	ASSEMBLY POINT IDENTIFIED ON GROUND LOCATION	YES
58	LIST OF OTHER STAFF TRAINED FOR HANDLING FIRE RELATED EMERGENCIES	SANDIP MUNDHE, RAJESH CHOPADE , DHIRAJ CHAWARE, GOPAL BHOMBE
59	WHETHER ADEQUATE FIRE & SAFETY DIRECTIONAL SIGNAGES BOARDS INSTALLED (YES/NO)	NO
60	NO. OF AMBULANCES IF ANY WITH CAPACITY	NA
61	NO. OF OTHER VEHICLES, THAT CAN BE UTILIZED IN CASE OF EMERGENCY	2 NO.
62	NO.OF TYPES OF SMOKE MASKS	
63	WHETHER ASSEMBLY POINT IS MARKED CLEARLY- YES/NO	YES
64	IS LICENSED AGENCY APPOINTED FOR SIX MONTHLY INSPECTION-YES/NO.	YES
65	NAME AND DETAILS OF LICENSED AGENCY	OYSTER INFRACON PVT. LTD.
66	ADDITIONAL OBSERVATIONS, IF ANY	
67	RECOMMENDATIONS IF ANY	AS PER ANNEXURE 2
	(NOTE: - FOR DETAILED OBSERVATIONS AND RECOMMENDATIONS SEPARATE SHEET SHOULD BE ATTACHED IF NECESSARY)	


Audit By:


Audit By:

OYSTER INFRACON PVT. LTD.  
LICENCE NO. - MFS-LA/2021/RF-271  
LICENCE NO. - MFS-LA/2021/RD-249

  
NAME & SIGNATURE OF THE INSPECTING OFFICER  
PRANAY TADSE (M:+91-95619 26002)

OYSTER INFRACON PVT. LTD.

  
Manager  
Yashodham Public School  
Malkapur Dist. Buldhana (M.S.)  
BUILDING INCHARGE

  
Principal,  
Yashodham Public School,  
MALKAPUR

  
Manager  
Yashodham Public School  
Malkapur Dist. Buldhana (M.S.)

B2

**ANNEXURE 2**  
**INSPECTION REPORT**

1 **Name & Address of the Building** YASHODHAM PUBLIC SCHOOL, YASHODHAM, WAKODI, MALKAPUR, DIST-BULDHANA - 443101

2 **Type of Occupancy** SCHOOL BUILDING - B1 TYPE

3 **Details of previous Fire NOC Letter No.** जा.क्र./मनपा/अज्जीशमन/६९८/२०२१, दिनांक : ०४/०९/२०२१

4 **Fire Safety directives letter No** NIL

5 **Date of Inspection** 14-08-2023

6 **Names of the Inspecting Officers/ AGENCY** OYSTER INFRACON PVT. LTD.

7 **Names and Designation of Officers** MR. PRANAY TADSE - SR. PROJECT ENGINEER  
if any, representing the Owner/ Occupier of the Building MR. B RAVISHANKAR MO:7588343972

8 **Year of Construction** 2013 (GF + 1st FL) & 2023 ( 2nd FL)

S#	MINIMUM STANDARDS FOR FIRE PREVENTION AND FIRE SAFETY	REQUIREMENT AS PER NBC 2005	PROVIDED AT SITE	REMARKS MEETS/DOESN'T MEET REQUIREMENT
1	Access to building			
	Road width	6 MTRS	YES	MEETS
	Gate width	1.5 MTR	YES	MEETS
	Width of internal road	NOT SPECIFIED	N. A.	
2	Means of egress			
	Number of staircases	NOT SPECIFIED	03 NO'S	MEETS
	Upper Floors	NOT SPECIFIED	02 NO'S	MEETS
	Basements	NOT SPECIFIED		
	Width of staircases			
	Upper Floors	NOT SPECIFIED	1.5 MTR & 1.0MTR	MEETS
	Basements	NOT SPECIFIED	N. A.	
	Protection of exits			
	Fire check door	NOT SPECIFIED	N. A.	
	Pressurization	NOT SPECIFIED	N. A.	
	No. of continuous staircases to terrace	ONE	ONE	MEETS
	Staircase lobby	NOT SPECIFIED	1.500 MTRS.	MEETS
	Width of Corridor	NOT SPECIFIED	7.300 MTR	MEETS
	Door Size	1 MTR	YES	MEETS
3	Compartmentation	NOT SPECIFIED	N. A.	
	Fire check door	---		
	Sealing of electrical shafts	---		
	Fire Rating of shaft door	---		
	Size of compartment	---		
	Fire Dampers	---		
4	Smoke Management System.	NOT REQUIRED	N. A.	
	Basements	30A/C PER HOUR		
	Upper floors	12A/C PER HOUR		

*Pranay Tadse*  
**Pranay Tadse**  
**Project Engineer**  
**Yashodham Public School,**  
**MALIKPUR**

*Manager*  
**Manager**  
**Yashodham Public School**  
**Malkapur Dist. Buldhana (A.S)**

*Pranay Tadse*  
**Pranay Tadse**

**FIRE FIGHTING SYSTEM | FIRE DETECTION SYSTEM | PASSIVE FIRE PROTECTION SYSTEM | PROJECT CONSULTANCY | FABRICATION & ERECTION | DESIGN & DEVELOPMENT**

**Regd. Office** : 2249/B 23-24, Shrikrushna Nagar, Nagpur- 440 009. (Maharashtra)  
**Branch Office** ♦ : Plot No. 6, Rajiv Gruh Nirman Housing Society, Ashtavinayak Nagar, Jaitala Road, Nagpur - 440036 (Maharashtra)  
♦ : 3. Swapnalok Complex, Near Inox Multiplex, Wardhaman Nagar, Nagpur - 440008 (Maharashtra)

S#	MINIMUM STANDARDS FOR FIRE PREVENTION AND FIRE SAFETY	REQUIREMENT AS PER NBC 2005	PROVIDED AT SITE	REMARKS MEETS/DOESN'T MEET REQUIREMENT
5	Fire Extinguishers	REQUIRED	YES	MEETS
	Total Numbers	NOT SPECIFIED	14 NOS.	MEETS
	Types	ABC/CO2/DCP	ABC/CO2	MEETS
	IS marking	ISI MARKED	YES	MEETS
6	First-Aid Hose Reels.	REQUIRED	YES PROVIDED	MEETS
	Total numbers on each floor	AS PER AREA	01 NOS. ON EACH FLOORS	MEETS
	Length of hose reel hose	30 MTRS	YES	MEETS
	Nozzle diameter	5 MM	63 MM	MEETS
7	Automatic Fire detection and Fire alarm.	NOT REQUIRED	YES, FIRE ALARM SYSTEM PROVIDED	MEETS
	Type of Detectors	SMOKE/ HEAT		
	Location of Main Panel	G.F.		
	Location of Repeater Panel	---		
	Alternate source of power	---	24V DC BATTERY	MEETS
8	Hooters' Location	GF	ON EACH FLOORS	MEETS
	Manually Operated Electrical Fire Alarm.	NOT REQUIRED	N. A.	
9	Public Address System.	NOT SPECIFIED	N. A.	
10	Automatic Sprinkler System.	NOT REQUIRED	N. A.	
	Basement	---		
	Upper Floor	---		
11	Sprinkler above false ceiling	---		
	Internal Hydrants	NOT REQUIRED	N. A.	
	Size of riser/down-comer	---		
	Number of hydrants per floor	---		
12	Hose Box	---		
	Yard Hydrants.	NOT REQUIRED	N. A.	
	Total Number of Hydrants	---		
13	Hose Box	---		
	Pumping Arrangements.			
13	Ground Level	NOT REQUIRED	N. A.	
	Discharge of Main Pump	---		
	Head of Main pump	---		
	Number of main pumps	---		
	Jockey Pump out put	---		
	Jockey pump head	---		
	Standby / Diesel Engine Pump out put	---		
	Standby / Diesel Engine Pump Head	---		
	Auto Starting/ Manual stopping	---		
	Pump House Access	---		
	Terrace level	REQUIRED	PROVIDED	MEET
	Discharge of pump	450 LPM	900 LPM	MEET
	Head of the pump	36 MTR.	YES,	MEET
	Power Supply	---	ALTERNATE POWER SUPPLY BY D. G. SET	MEET
Auto Starting of pump	---			
14	Captive Water Storage for fire fighting	NOT EQUIRED		
	Underground tank capacity	---		
	Draw-off connection	---		
	Fire service inlet	REQUIRED	YES, ON ENTRANCE OF BUILDING	MEET
	Access to tank	---		
	Overhead Tank capacity (EXCLUSIVELY FOR FIRE FIGHTING)	10,000 LTRS	10,000 LTRS	MEETS

Principal,  
Yashodham Public School  
Malkepur Dist. Buldana (M.S.)

Manager  
Yashodham Public School  
Malkepur Dist. Buldana (M.S.)





S#	MINIMUM STANDARDS FOR FIRE PREVENTION AND FIRE SAFETY	REQUIREMENT AS PER NBC 2005	PROVIDED AT SITE	REMARKS MEETS/DOESN'T MEET REQUIREMENT
15	Exit Signage	REQUIRED	PROVIDED AT SITE	MEETS
16	Provision of Lifts	NOT REQUIRED	N. A.	
	Pressurization of Lift Shaft	---		
	Pressurization of Lift lobby	---		
	Communication facility In lift Car	---		
	Fireman's Grounding Switch	---		
	Lift Signages	---		
17	Standby power supply	REQUIRED	D. G. SET PROVIDED AT SITE	MEETS
18	Refuge Area.	NOT APPLICABLE	YES, AT GROUND FLOOR	MEETS
	Total Area	---		
	Location	---		
19	Fire Control Room	NOT REQUIRED	N. A.	
	Control Panel	---		
	Detector System	REQUIRED		
	Flow Switch Panel	---		
	PA System Panel	---		
	Battery backup, if any	REQUIRED	D. G. SET PROVIDED AT SITE	MEETS
	Building Floor Plans	---		
20	Special Fire Protection Systems for Protection of Special Risks.	NOT REQUIRED		

The fire protection systems should be provided. And Keeping in view the extent of compliance of the minimum standards on fire prevention and fire safety required under the Rules.

The fire protection equipment mentioned above is provided at the time of inspection of the building / premises. Considering the limits of compliance with the minimum standards of fire prevention and fire safety required by the rules, it is proposed as follows. - NIL.

Audit By:

**OYSTER INFRACON PVT. LTD.**  
 LICENCE NO. - MFS-LA/2021/RF-271  
 LICENCE NO. - MFS-LA/2021/RD-249

NAME & SIGNATURE OF THE INSPECTING OFFICER

PRANAY TADSE (M:+91-95619 26002)

OYSTER INFRACON PVT. LTD.

Manager  
 Yashodham Public School  
 Malkapur, Dist. Buldana. (M.S)

Principal,  
 Yashodham Public School,  
 MALKAPUR

Manager  
 Yashodham Public School  
 Malkapur, Dist. Buldana. (M.S)

C1

<b>ANNEXURE 1</b>		
<b>FIRE SAFETY CHECK LIST FOR BUILDINGS</b>		
S#	PARTICULARS	DESCRIPTION
1	NAME OF THE BUILDING	YASHODHAM PUBLIC SCHOOL
2	USE OF BUILDING	B1 - TYPE - SCHOOL BUILDING
3	ADDRESS	YASHODHAM PUBLIC SCHOOL, YASHODHAM, WAKODI, MALKAPUR, DIST-BULDHANA - 443101
4	TELEPHONE NO.	07267-226285
5	E-MAIL -ID	ypsmalkapur@gmail.com
6	WEBSITE ADDRESS	
7	NAME OF THE BUILDING IN-CHARGE AND TEL. NO.	MR. B RAVISHANKAR MO:7588343972
8	NAME OF ADMINISTRATIVE HEAD AND TEL.NO.	DR.VAIBHAV B. MAHAJAN MO:9765582888
9	BUILDING INCHARGE NAME & TEL. NO.	MR. B RAVISHANKAR MO:7588343972
10	BUILDING OWNER/OCCUPIERS NAME & ADDRESS	MRS. SULOCHANA SWARUPCHAND CHAWARE, VRINDAVAN NAGAR, MALKAPUR, DIST.: BULDANA - 443 101
11	BUILDING TYPE-GOVT/ SEMI GOVT/PRIVATE/ MUNICIPAL/TRUSTEE/CHARITY	PRIVATE
12	BUILDING SPECIALITY IN ANY	B1 - TYPE - SCHOOL BUILDING
13	BUILDING OCCUPANCY TOTAL NOS.	500 No's STUDENTS
14	<b><u>BUILDING STRUCTURAL DETAILS</u></b>	
a)	BUILDING HEIGHT	9.9 MTR. Building: 'C'
b)	NO OF FLOORS	GR + 02 Floors
c)	TOTAL BUILT-UP AREA	965 SQ.MTR APPROX.
d)	APPROACH ROAD	06 MTRS.
e)	BUILDING OPEN SPACES	
i	EAST	RESIDENTIAL PLOTS
ii	WEST	RESIDENTIAL PLOTS
iii	SOUTH	SCHOOL GROUND
iv	NORTH	6.00 MTR ROAD
f)	NO.OF EXITS (GATE /DOORS/TERRACE ECT.)	EXITS: 02 NO'S
g)	EXIT WIDTH	3.7 MTRS. & 1.00 MTRS.
H)	NO. OF STAIRCASE	01 NO'S
I)	STAIRCASE WIDTH	1.4 MTRS.
J)	NATURE OF FLOORING ON EXIT ROUTES	TILES
k)	PARTITIONS IF ANY	NA
l)	MATERIAL USED FOR PARTITIONS	NA
m)	BASEMENT IF ANY	NO
n)	NO. OF BASEMENTS	NO
o)	AREA OF BASEMENT	N.A.
15	BASEMENT UTILITY	N.A.
16	MATERIAL STORED IF ANY IN BASEMENT	N.A.
17	TOTAL NO OF ROOMS/FLOORS	18 ROOMS (GR.: 06 NO'S & 1ST: 06 NO'S, & 2ND: 06 Nos )
18	TOTAL NO. OF ROOMS IN BUILDING	18 ROOM.

*[Signature]*  
Principal,  
Yashodham Public School,  
MALKAPUR

*[Signature]*  
Manager  
Yashodham Public School  
Malkapur Dist. Buldhana. (M.S)

*[Signature]*

**FIRE FIGHTING SYSTEM | FIRE DETECTION SYSTEM | PASSIVE FIRE PROTECTION SYSTEM | PROJECT CONSULTANCY | FABRICATION & ERECTION | DESIGN & DEVELOPMENT**


**Regd. Office** : 2249/B 23-24, Shrikrushna Nagar, Nagpur- 440 009. (Maharashtra)  
**Branch Office** ♦ : Plot No. 6, Rajiv Gruh Nirman Housing Society, Ashtavinayak Nagar, Jaitala Road, Nagpur - 440036 (Maharashtra)

S#	PARTICULARS	DESCRIPTION
19	NO OF TOILETS PER FLOOR	GR: 02 & 1ST: 02 No's & 2 ID : 02 Nos
20	EXTERIOR FACADING/CLADDING OF BUILDING-GLASS	
21	OVER HEAD WATER TANK CAPACITY	11,000 LTRS.
22	UNDERGROUND WATER TANK CAPACITY	7,000 LTRS.
23	BUILDING INTERIOR NATURE	
24	NO.OF LIFTS WITH CAPACITY	NO.
a)	PASSANGER LIFTS	NO
b)	FIRE LIFTS	NO
c)	STRETCHER LIFTS IF ANY	NO
d)	ANY OTHER LIFTS	NA
25	ELECTRICAL WIRING / INSTALLATION AUDIT / ELECTRICAL INSPECTORS	NO
26	ANNUAL TEST REPORT-COPY	NO
27	INTERIOR LOCATION	
28	CANTEEN/PANTRY/KITCHEN LOCATION & AREA	N.A.
29	FUEL USED NO. OF CYLINDERS LOCATION	NO
30	ANY OTHER ASSEMBLY AREAS/LOCATION	MAIN ENTRANCE OF BUILDING
31	STORE ROOM LOCATION	GR. FLOOR
32	STORE ROOM AREA STORAGE TYPE	11.00 SQ. MTR. DOCUMENTS ONLY
33	TRANSFORMER/GENERATOR LOCATION WITH CAPACITY & TYPE	GENERATOR:01 NO'S (25KVA)
34	AIR-CONDITIONING TYPE WINDOW/SPLIT/CENTRAL AC ETC	NO
35	BUILDING UTILITIES	B1 - TYPE - SCHOOL BUILDING
36	NO. OF CINEMA THEATRES /HALLS/OPERATION THEATRES	NO
37	TOTAL NO OF SEATING ARRANGEMENT /BENCHES	500 SEATINGS
38	NO.OF MAX OCCUPANCIES IN BUILDING	500 STUDENTS + STAFFS
39	NO.OF VISITORS (FLOATING POPULATION)	500 STUDENTS + STAFFS
40	MACHINERY IF ANY	N.A.
a)	NAME	N.A.
b)	QTY	N.A.
c)	STORAGE	N.A.
d)	PLACE ETC	N.A.
41	TYPE/DETAILS OF MATERIAL STORED IN STOREROOM (ACIDS/ALAKALIS/TOXIC/INFLAMMABLE ETC)	ONLY DOCUMENTS
42	LPG/CNG ETC GAS STORAGE DETAILS (GAS NAME QTY ETC)	NO
43	GAS UTILITY	N.A
44	TOTAL NO OF EMPLOYEES	125 NO'S
45	NO OF TOTAL STAFF SHIFT WISE	GENERAL: 124 NIGHT: 01
46	NO. OF SECURITY STAFF SHIFWISE	DAY: 00 NO'S. & NIGHT: 01 NO'S
47	PERMISSIONS & APPROVALS	
48	WHETHER BUILDING PLANS SANCTIONED BY COMPETENT AUTHORITY/GOVT (COPY OF SANCTIONED PLAN)	YES
49	WHETHER FINAL NOC OBTAINED IF YES SUBMIT COPY	N.A.
50	BUILDING COMPLETION CERTIFICATE OBTAINED (YES/NO), IF YES. SUBMIT COPY	N.A.

File Audit Report

*[Signature]*  
Principal,  
Yashodham Public School,  
MALKAPUR

*[Signature]*  
Manager  
Yashodham Public School  
Malkepur, Dist. Buldana. (M.S.)





S#	PARTICULARS	DESCRIPTION
51	<b>FIRE FIGHTING INSTALLATION DETAILS</b>	<b>FIRE EXTINGUISHERS: 09 NO'S ONLY</b>
52	<b>ACTIVE FIRE PROTECTION</b>	FIRE EXTINGUISHERS: 09 NO'S ONLY
a)	WHETHER FIXED FIRE FIGHTING SYSTEM (RISER - DOWN COMER) INSTALLED YES/NO	<b>YES, DOWN RISER WITH HOSEREEL ON EACH FLOORS</b>
b)	FIRE SMOKE DETECTORS /SPRINKLERS/MANNUAL CALL POINTS/PA SYSTEM INSTALLED	<b>YES, MANUALLY OPERATED FIRE ALARM WITH MCP &amp; HOOTERS ON EACH FLOOR!</b>
c)	SPECIAL PUBLIC ADDRESS SYSTEM INSTALLED IF ANY	<b>NO</b>
d)	IF YES, IS IT IN OPERATING /WORKING CONDITION	<b>NA</b>
e)	FIRE FIGHTING PUMP DETAILS (ELECTRIC/DIESEL, OUTPUT, HP, HEAD, ETC)	<b>YES,</b>
i)	MAIN PUMP	<b>01 NOS.</b>
ii)	JOCKEY PUMP	<b>NO</b>
iii)	SPRINKLER PUMP	<b>NO</b>
iv)	STAND BY PUMP	<b>NO</b>
v)	DIESEL PUMP	<b>NO</b>
f)	EMERGENCY BACKUP ARRANGEMENT	<b>NO</b>
g)	WHETHER FIRE SYSTEM & EMERGENCY LIGHTING ATTACHED TO EMERGENCY BACKUP	<b>NA</b>
h)	FIRE FIGHTING WATER TANK CAPACITY	<b>10,000 LTRS</b>
i)	IF YES, DATE OF LAST TESTING	<b>NO</b>
j)	NO.OF LOCATION OF FIRE EXTINGUISHERS	<b>09 NOS</b>
	TYPE OF EXTINGUISHERS LAST INSPECTED	<b>ABC-06Kg. = 01NO'S, ABC-04 = 05No's, ABC-05KG = 02 NO'S, CO2-4.5KG. = 01NO'S DT.: 14/08/2023</b>
53	<b>WHETHER AUTOMATIC FIRE DAMPERS PROVIDED IN CENTRAL AC DUCTS</b>	<b>NO</b>
a)	CONNECTED TO DETECTION SYSTEM	<b>NA</b>
b)	LAST INSPECTED / MAINTENANCE CARRIED OUT	<b>NA</b>
54	<b>OTHER INFORMATION</b>	
a)	FIRE LIFT, IF ANY	<b>NO</b>
b)	ELECTRICAL MCB/ACB/ELCB PROVIDED	<b>YES</b>
c)	FIRE STOP /RESISTING DOORS PROVIDED	<b>NO</b>
d)	IF YES, RATING OF DOORS HRS	<b>NA</b>
e)	WHETHER FIRE PLANS INSTALLED IN EACH WARD	<b>NO</b>
f)	WHETHER FIRE EMERGENCY INSTRUCTIONS BOARD INSTALLED ON EVERY FLOOR	<b>NO</b>
g)	VERTICAL SHIFTS SEALED	<b>NA</b>
h)	FIRE STAFF PROVIDED IF YES, NOS.	<b>NO</b>
i)	NO. OF STAFF TRAINED FOR BASIC FIRE FIGHTING	<b>05 NO'S</b>
j)	SECURITY STAFF TRAINED	<b>01 NO'S</b>
55	<b>FIRE PREVENTION &amp; AWARENESS MEASURES</b>	
a)	FIRE MOCK DRILL CONDUCTED IF ANY - YES/NO	<b>YES</b>
b)	IF YES, DATE OF RECENT DRILL-SUBMIT REPORT	<b>Date: 09/12/2022 , Photos Attached</b>
c)	WHETHER EVACUATION DRILL CONDUCTED, YES/NO	<b>NO</b>
d)	IF YES, INDICATE PERIODICITY.	<b>NO</b>
e)	IF YES, DATE OF RECENT DRILL-SUBMIT REPORT	<b>NO</b>
f)	ON SITE EMERGENCY PLAN-ATTACH COPY	<b>NO</b>

*[Signature]*  
Principal,  
Yashodham Public School,  
MALKAPUR.

*[Signature]*  
Manager  
Yashodham Public School  
Malkepur,Dist.Buldana.(M.S.)



S#	PARTICULARS	DESCRIPTION
g)	RESPONSIBLE PERSON IN CASE OF EMERGENCY	<b>SUPPORTING STAFF / RESIDENT WATCHMEN</b>
i)	NAME,	NA
ii)	ADDRESS	<b>ON DUTY STAFF</b>
iii)	MOB NO.	NA
iv)	IS THE FIRE OFFICER EMPLOYED?,	NO
h)	DETAILS ABOUT FIRE OFFICER	NO
i)	NAME	NA
ii)	ADDRESS	NA
iii)	MOB NO.	NA
iv)	QUALIFICATION & EXPERIENCE	NA
i)	SAFETY OFFICER/SECURITY OFFICER	NA
i)	NAME	NA
ii)	ADDRESS	NA
iii)	MOB NO.	NA
iv)	QUALIFICATION & EXPERIENCE	NA
56	REFUGE AREA, IF ANY LOCATION AREA ETC.	
57	ASSEMBLY POINT IDENTIFIED ON GROUND LOCATION	YES
58	LIST OF OTHER STAFF TRAINED FOR HANDLING FIRE RELATED EMERGENCIES	SANDIP MUNDHE, RAJESH CHOPADE , DHIRAJ CHAWARE, GOPAL BHOMBE
59	WHETHER ADEQUATE FIRE & SAFETY DIRECTIONAL SIGNAGES BOARDS INSTALLED (YES/NO)	NO
60	NO. OF AMBULANCES IF ANY WITH CAPACITY	NA
61	NO. OF OTHER VEHICLES, THAT CAN BE UTILIZED IN CASE OF EMERGENCY	2
62	NO.OF TYPES OF SMOKE MASKS	
63	WHETHER ASSEMBLY POINT IS MARKED CLEARLY-YES/NO	YES
64	IS LICENSED AGENCY APPOINTED FOR SIX MONTHLY INSPECTION-YES/NO.	YES
65	NAME AND DETAILS OF LICENSED AGENCY	OYSTER INFRACON PVT. LTD.
66	ADDITIONAL OBSERVATIONS, IF ANY	
67	RECOMMENDATIONS IF ANY	AS PER ANNEXTURE 2
	(NOTE: - FOR DETAILED OBSERVATIONS AND RECOMMENDATIONS SEPARATE SHEET SHOULD BE ATTACHED IF NECESSARY)	

Audit By:

OYSTER INFRACON PVT. LTD.  
 LICENCE NO. MFS-LA/2021/RF-271  
 LICENCE NO. MFS-LA/2021/RD-249

NAME & SIGNATURE OF THE INSPECTING OFFICER

PRANAY TADSE (M:+91-95619 26002)

OYSTER INFRACON PVT. LTD.

*[Signature]*  
 Manager  
 Yashodham Public School  
 Malkapur, Dist. Buldana, (M.S.)

*[Signature]*  
 Principal,  
 Yashodham Public School,  
 MALKAPUR

*[Signature]*  
 Manager  
 Yashodham Public School  
 Malkapur, Dist. Buldana, (M.S.)



C2

**ANNEXURE 2**  
**INSPECTION REPORT**

<b>1 Name &amp; Address of the Building</b>	<b>YASHODHAM PUBLIC SCHOOL, YASHODHAM, WAKODI, MALKAPUR, DIST-BULDHANA - 443101</b>
<b>2 Type of Occupancy</b>	<b>SCHOOL BUILDING - B1 TYPE</b>
<b>3 Details of previous Fire NOC Letter No.</b>	<b>जा.क्र./मनपा/अग्नीशमन/६९८/२०२१, दिनांक : ०४/०९/२०२१</b>
<b>4 Fire Safety directives letter No</b>	<b>NIL</b>
<b>5 Date of Inspection</b>	<b>14-08-2023</b>
<b>6 Names of the Inspecting Officers/ AGENCY</b>	<b>OYSTER INFRACON PVT. LTD.</b>
<b>7 Names and Designation of Officers</b>	<b>MR. PRANAY TADSE - SR. PROJECT ENGINEER</b>
<b>if any, representing the Owner/ Occupier of the Building</b>	<b>MR. B RAVISHANKAR MO:7588343972</b>
<b>8 Year of Construction</b>	<b>2015 - 16</b>

S#	MINIMUM STANDARDS FOR FIRE PREVENTION AND FIRE SAFETY	REQUIREMENT AS PER NBC 2005	PROVIDED AT SITE	REMARKS MEETS/DOESN'T MEET REQUIREMENT
1	Access to building			
	Road width	6 MTRS	YES	MEETS
	Gate width	1.5 MTR	YES	MEETS
	Width of internal road	NOT SPECIFIED	N.A.	
2	Means of egress			
	Number of staircases	NOT SPECIFIED	01 NO'S	MEETS
	Upper Floors	NOT SPECIFIED	01 NO'S	MEETS
	Basements	NOT SPECIFIED		
	Width of staircases			
	Upper Floors	NOT SPECIFIED	1.4 MTR	MEETS
	Basements	NOT SPECIFIED	N.A.	
	Protection of exits			
	Fire check door	NOT SPECIFIED	N.A.	
	Pressurization	NOT SPECIFIED	N.A.	
No. of continuous staircases to terrace	ONE	ONE	MEETS	
Staircase lobby	NOT SPECIFIED	1.500 MTRS.	MEETS	
Width of Corridor	NOT SPECIFIED	3.700 MTR	MEETS	
Door Size	1 MTR	YES	MEETS	
3	Compartmentation	NOT SPECIFIED	N.A.	
	Fire check door	---		
	Sealing of electrical shafts	---		
	Fire Rating of shaft door	---		
	Size of compartment	---		
Fire Dampers	---			
4	Smoke Management System.	NOT REQUIRED	N.A.	
	Basements	30A/C PER HOUR		
	Upper floors	12A/C PER HOUR		

Fire Audit Report

*Principal,*  
Yashodham Public School,  
MALKAPUR.

*Manager*  
Yashodham Public School  
Malkapur, Buldhana (M.S.)

*Pradise*

Page 1 of 1



S#	MINIMUM STANDARDS FOR FIRE PREVENTION AND FIRE SAFETY	REQUIREMENT AS PER NBC 2005	PROVIDED AT SITE	REMARKS MEETS/DOESN'T MEET REQUIREMENT
5	Fire Extinguishers †	REQUIRED	YES	MEETS
	Total Numbers	NOT SPECIFIED	09 NOS	MEETS
	Types	ABC/CO2/DCP	ABC/CO2	MEETS
	IS marking	ISI MARKED	YES	MEETS
6	First-Aid Hose Reels.	REQUIRED	PROVIDED AT SITE	MEETS
	Total numbers on each floor	AS PER AREA	01 NOS. on EACH FLOOR	MEETS
	Length of hose reel hose	30 MTRS	30 MTRS	MEETS
	Nozzle diameter	5 MM	63 MM	MEETS
7	Automatic Fire detection and Fire alarm.	NOT REQUIRED	YES, FIRE ALARM PANEL	MEETS
	Type of Detectors	SMOKE/ HEAT		
	Location of Main Panel	G.F.	AT GROUND FLOOR	MEETS
	Location of Repeater Panel	---		
	Alternate source of power	---	24V DC BATTERY	MEETS
	Hooters' Location	GF	01 NOS. on EACH FLOOR	MEETS
8	Manually Operated Electrical Fire Alarm.	NOT REQUIRED	N.A.	
9	Public Address System.	NOT SPECIFIED	N.A.	
10	Automatic Sprinkler System.	NOT REQUIRED	N.A.	
	Basement	---		
	Upper Floor	---		
	Sprinkler above false ceiling	---		
11	Internal Hydrants	NOT REQUIRED	N.A.	
	Size of riser/down-comer	---		
	Number of hydrants per floor	---		
	Hose Box	---		
12	Yard Hydrants.	NOT REQUIRED	N.A.	
	Total Number of Hydrants	---		
	Hose Box	---		
13	Pumping Arrangements.			
	Ground Level	NOT REQUIRED	N.A.	
	Discharge of Main Pump	---		
	Head of Main pump	---		
	Number of main pumps	---		
	Jockey Pump out put	---		
	Jockey pump head	---		
	Standby / Diesel Engine Pump out put	---		
	Standby / Diesel Engine Pump Head	---		
	Auto Starting/ Manual stopping	---		
	Pump House Access	---		
Terrace level		REQUIRED	PROVIDED AT SITE	MEETS
	Discharge of pump	450 LPM	900 LPM	MEETS
	Head of the pump	36 MTR.	36 MTRS	MEETS
	Power Supply	---		
	Auto Starting of pump	---		



S#	MINIMUM STANDARDS FOR FIRE PREVENTION AND FIRE SAFETY	REQUIREMENT AS PER NBC 2005	PROVIDED AT SITE	REMARKS MEETS/DOESN'T MEET REQUIREMENT
14	Captive Water Storage for fire fighting	NOT EQUIRED	N.A.	
	Underground tank capacity	---		
	Draw-off connection	---		
	Fire service inlet	REQUIRED	01 NOS. AT ENTRANCE OF BUILDING	MEETS
	Access to tank	---		
	Overhead Tank capacity (EXCLUSIVELY FOR FIRE FIGHTING)	10,000 LTRS	PROVIDED AT SITE	MEETS
15	Exit Signage	REQUIRED	PROVIDED AT SITE	MEETS
16	Provision of Lifts	NOT REQUIRED	N.A.	
	Pressurization of Lift Shaft	---		
	Pressurization of Lift lobby	---		
	Communication facility In lift Car	---		
	Fireman's Grounding Switch	---		
	Lift Signages	---		
17	Standby power supply	REQUIRED	D. G. SET PROVIDED AT SITE	MEETS
18	Refuge Area.	NOT APPLICABLE	N.A.	
	Total Area	---		
	Location	---		
19	Fire Control Room	NOT REQUIRED	N.A.	
	Control Panel	---		
	Detector System	REQUIRED		
	Flow Switch Panel	---		
	PA System Panel	---		
	Batter backup, if any	REQUIRED	D. G. SET PROVIDED AT SITE	MEETS
	Building Floor Plans	---		
20	Special Fire Protection Systems for Protection of Special Risks.	NOT REQUIRED	N.A.	

The fire protection systems should be provided. And Keeping in view the extent of compliance of the minimum standards on fire prevention and fire safety required under the Rules.


The fire protection equipment mentioned above is provided at the time of inspection of the building / premises. Considering the limits of compliance with the minimum standards of fire prevention and fire safety required by the rules, it is proposed as follows. - NIL

Audit By:

**OYSTER INFRACON PVT. LTD.**

LICENCE NO. - MFS-LA/2021/RP-271


LICENCE NO. - MFS-LA/2021/RD-249



**NAME & SIGNATURE OF THE INSPECTING OFFICER**

PRANAY TADSE (M:+91-95619 26002)

**OYSTER INFRACON PVT. LTD.**



**Manager**  
Yashodham Public School  
Malkepur, Dist. Buldana. (M.S)